

REGAN YOUNG ENGLAND BUTERA

REFERENDUMS • ENGINEERING • ARCHITECTURE • DESIGN

456 HIGH ST. • MT. HOLLY, NJ 08060 USA
(609) 265-2652 • 21AI00912100 • www.RYEBREAD.com



ADDENDUM - 02

DATE:.....25 May 2022
FROM:..... Scott England, AIA
VIA: Email & Facsimile

SUBJECT:
ADDENDUM #2
FACILITY IMPROVEMENTS
HAINESPORT TOWNSHIP SCHOOL
RYEBREAD Project #5662A-C

This addendum is issued to clarify, correct or supplement the Documents as originally issued and will become a part of the Contract. Receipt thereof shall be acknowledged by Bidders in space provided in the Form of Bid. Failure to acknowledge this Addendum on the official Form of Bid may be cause for rejection of Bid.

2.01 **AMENDMENT: Resilient Vinyl Athletic Flooring:** Delete all references to a loose laid installation of the resilient vinyl athletic flooring.

The flooring must be installed in a full-bed of adhesive as required by the flooring manufacturer to comply with the manufacturer’s installation requirements and the specified warranty.

2.02 **AMENDMENT: Bid Date Extension:** As a result of this Addendum, the Bid Opening Date has been extended to now be **07 June 2022 at 2:00 PM.**

END OF ADDENDUM 02