

REGAN YOUNG ENGLAND BUTERA

REFERENDUMS • ENGINEERING • ARCHITECTURE • DESIGN



ADDENDUM - 01

456 HIGH ST. • MT. HOLLY, NJ 08060 USA
(609) 265-2652 • 21AI00912100 • www.RYEBREAD.com

DATE: Tuesday, 04 November 2025

FROM: Angelo P. Butera, AIA

VIA: Facsimile

SUBJECT:

RYEBREAD Project #5760C

MAGOWAN ELEMENTARY SCHOOL KITCHEN
ALTERATIONS

NJDOE # 05-1280-050

This addendum is issued to clarify, correct or supplement the Documents as originally issued and will become a part of the Contract. Receipt thereof shall be acknowledged by Bidders in space provided in the Form of Bid. Failure to acknowledge this Addendum on the official Form of Bid may be cause for rejection of Bid.

- 1.01. Change: The last day for questions has been extended to 1:00 PM Monday, 24 November and the bids will be received no later than 3:00 PM prevailing time, on Tuesday, 09 December 2025.
- 1.02. Clarification: Section 002000 - Form of Bid, Bidder shall correlate all required documents in the order listed in the "Documents Accompanying Bid" as found on the Form of Bid and place an "X" in the box next to each item provided. Failure to provide all required documents and required number of copies may be cause for disqualification and rejection of bid.
- 1.03. Clarification: Section 237432 - Range Hood Exhaust Systems, ductwork shall be 18 inch by 10 inch as indicated on dwg sht H-100 & shall be constructed of 16 gauge black steel with welded joints & seams. All ductwork shall be insulated w/ two (2) layers of 3M Fire Barrier Duct Wrap or Arch'ts approved equal. The entire installation shall comply w/ Section 5 of the 2021 International Mechanical Code.
- 1.04. Clarification: Section 237434-3, Paragraph 1.10 C, the integration of RTU (DOAZ) controls into the exist'g BAS is a TRANE system installed by TOZOR TRANE (now PHILADELPHIA TRANE).
- 1.05. Clarification: Sht D101 – Construction Notes, the District's Fire Alarm vendor is as noted under the "Demolition" section.
- 1.06. Clarification: Contractor may place storage containers in the west parking lot beginning on 22 June 2026.
- 1.07. The list of current plan holders and addenda can be found at www.ryebread.com under the "Bidding" tab.

Including this page, Addendum 01 consists of (01) page(s).

END OF ADDENDUM 01