

DATE: Tuesday, 25 November 2025
FROM: Angelo P. Butera, AIA
VIA: Electronic Mail

SUBJECT:

RYEBREAD Project #5760C
MAGOWAN ELEMENTARY SCHOOL KITCHEN
ALTERATIONS
NJDOE # 05-1280-050

This addendum is issued to clarify, correct or supplement the Documents as originally issued and will become a part of the Contract. Receipt thereof shall be acknowledged by Bidders in space provided in the Form of Bid. Failure to acknowledge this Addendum on the official Form of Bid may be cause for rejection of Bid.

- 3.01. Clarification: Section 002000 - Form of Bid, Bidder shall correlate all required documents in the order listed in the "Documents Accompanying Bid" as found on the Form of Bid and place an "X" in the box next to each item provided. Failure to provide all required documents and required number of copies may be cause for disqualification and rejection of bid.
- 3.02. Clarification: The Grease Interceptor (GI-1) as found in the Plumbing Equipment Schedule on Dwg P-200 and the Grease Removal Device (GI-1) specified in Section 221323-2.1.A of the Project Manual are not the same. The Grease Interceptor (GI-1) as found in the Plumbing Equipment Schedule on Dwg P-200 shall govern.
- 3.03. The list of current plan holders and addenda can be found at www.ryebread.com under the "Bidding" tab.

Including this page, Addendum 3 consists of (01) page(s).

END OF ADDENDUM 03