

# REGAN YOUNG ENGLAND BUTERA

REFERENDUMS • ENGINEERING • ARCHITECTURE • DESIGN

456 HIGH ST. • MT. HOLLY, NJ 08060 USA  
(609) 265-2652 • 21AI00912100 • www.RYEBREAD.com



## ADDENDUM - 01

DATE: ..... 02 October 2025

FROM: ..... Scott England, AIA

VIA: ..... Electronic File Share

### SUBJECT:

**ADDENDUM #01**

LINBOE HS WINDOWS REPLACEMENT

RYEB Project #5773D

This addendum is issued to clarify, correct or supplement the Documents as originally issued and will become a part of the Contract. Receipt thereof shall be acknowledged by Bidders in space provided in the Form of Bid. Failure to acknowledge this Addendum on the official Form of Bid may be cause for rejection of Bid.

1.01. **ADDITION:** The following specification Sections were omitted from the bound Project Manual and are now included and attached:

1. Specification Section 000010 – TABLE OF CONTENTS: Consisting of 3 pages total.
2. Specification Section 081416 – FLUSH WOOD DOORS: Consisting of 6 pages total.
3. Specification Section 087100 – DOOR HARDWARE: Consisting of 14 pages total.
4. Specification Section 090190.52 MAINTENANCE REPAINTING: Consisting of 12 pages total.
5. Specification Section 090561.13 – MOISTURE VAPOR EMISSION CONTROL: Consisting of 6 pages total.
6. Specification Section 096513 – RESILIENT BASE AND ACCESSORIES: Consisting of 5 pages total.
7. Specification Section 096519 – LUXURY VINYL TILE FLOORING: Consisting of 6 pages total.
8. Specification Section 096813 – TILE CARPETING: Consisting of 6 pages total.
9. Specification Section 123661.16 – SOLID SURFACING WINDOWSILLS: Consisting of 3 pages total.

### ATTACHMENT:

1. All specifications referenced above.

Including this page, Addendum 01 consists of (62) page(s).

END OF ADDENDUM 01

WINDOWS REPLACEMENT - LINDENWOLD HIGH SCHOOL  
REGAN YOUNG ENGLAND BUTERA, PC PROJECT #5773D

SECTION 000010 - TABLE OF CONTENTS

All sections have page numbers prefixed by the section number, as page number 000000-3 for page 3 of Section 000000.

SECTION NUMBER	SECTION TITLE	# PAGES
-------------------	---------------	---------

**DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS**

000010	TABLE OF CONTENTS .....	3
000100	ADVERTISEMENT.....	3
001000	INSTRUCTIONS TO BIDDERS.....	14
002000	FORM OF BID .....	8
002513	PRE-BID MEETINGS .....	2
002800	CONSENT OF SURETY .....	1
002801	SURETY COMPANY & AGENCY INFORMATION.....	1
002850	AFFIRMATIVE ACTION EVIDENCE FOR CONSTRUCTION PROJECTS AND MANDATORY EQUAL OPPORTUNITY LANGUAGE .....	5
002900	OWNERSHIP DISCLOSURE STATEMENT .....	1
002905	EQUIPMENT CERTIFICATION.....	1
002950	NON-COLLUSION AFFIDAVIT .....	1
002960	NO MATERIAL CHANGE IN CIRCUMSTANCES .....	1
002970	CERTIFICATION OF NON-DEBARMENT FOR FEDERAL GOVERNMENT CONTRACTS.....	4
003113	CONTRACTOR INSURANCE REQUIREMENTS .....	3
004580	SWORN CONTRACTOR CERTIFICATION REQUIREMENTS .....	2
004595	PREVAILING WAGES CERTIFICATION FORM .....	1
004596	LOWEST BIDDER PREVAILING WAGE CERTIFICATION.....	2
005290	LIST OF PRIME SUBCONTRACTORS .....	2
006000	PROJECT FORMS.....	2
006001	BIDDER REQUEST FOR INFORMATION .....	1
007100	NOTICE TO PROCEED.....	1

**DIVISION 01 - GENERAL REQUIREMENTS**

	AIA GENERAL CONDITIONS AIA A201– 2017 .....	61
010003	PREVAILING WAGE RATES. ....	2
011000	SUMMARY .....	7
012100	ALLOWANCES.....	3
012300	ALTERNATES .....	2
012500	SUBSTITUTION PROCEDURES .....	4
012501	SUBSTITUTION REQUEST .....	2
012600	CONTRACT MODIFICATION PROCEDURES .....	3
012610.1	PRIME CONTRACTOR COR SUMMARY .....	1
012610.2	PRIME CONTRACTOR COR WORKSHEET.....	1
012620.1	SUBCONTRACTOR COR SUMMARY .....	1
012620.2	SUBCONTRACTOR COR WORKSHEET .....	1
012900	PAYMENT PROCEDURES.....	6

WINDOWS REPLACEMENT - LINDENWOLD HIGH SCHOOL  
 REGAN YOUNG ENGLAND BUTERA, PC PROJECT #5773D

1	012910	PAYROLL VERIFICATION AFFIDAVIT.....	1
2	012911	PARTIAL RELEASE OF LIENS .....	3
3	012920	BILL OF SALE/CERTIFICATION FOR STORED MATERIAL.....	3
4	013100	PROJECT MANAGEMENT AND COORDINATION .....	14
5	013200	CONSTRUCTION PROGRESS DOCUMENTATION.....	6
6	013300	SUBMITTAL PROCEDURES .....	10
7	013310	PROJECT START-UP SUBMITTALS .....	2
8	014000	QUALITY REQUIREMENTS .....	8
9	015000	TEMPORARY FACILITY AND CONTROLS .....	7
10	016000	PRODUCT REQUIREMENTS.....	7
11	017300	EXECUTION .....	10
12	017419	CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL.....	3
13	017700	CLOSEOUT PROCEDURES .....	6
14	017710	PROJECT CLOSEOUT SUBMITTALS .....	2
15	017721	MAINTENANCE BOND .....	2
16	017722	SUBCONTRACTOR GUARANTY .....	2
17	017823	OPERATION AND MAINTENANCE DATA .....	8
18	017839	PROJECT RECORD DOCUMENTS .....	5
19			
20	<b>DIVISION 02 – EXISTING CONDITIONS</b>		
21			
22	024119	SELECTIVE DEMOLITION.....	5
23			
24	<b>DIVISION 04 – MASONRY</b>		
25			
26	042000	UNIT MASONRY ASSEMBLIES .....	10
27			
28	<b>DIVISION 07 – THERMAL &amp; MOISTURE PROTECTION</b>		
29			
30	079200	JOINT SEALANTS.....	8
31			
32	<b>DIVISION 08 – OPENINGS</b>		
33			
34	081113	HOLLOW METAL FRAMES.....	7
35	081416	FLUSH WOOD DOORS .....	6
36	085113	ALUMINUM WINDOWS.....	9
37	087100	DOOR HARDWARE.....	
38	088813	FIRE RATED GLAZING .....	7
39			
40	<b>DIVISION 09 - FINISHES</b>		
41			
42	090190.52	MAINTENANCE REPAINTING.....	12
43	090561.13	MOISTURE VAPOR EMISSION CONTROL .....	6
44	096513	RESILIENT BASE AND ACCESSORIES .....	5
45	096519	LUXURY VINYL COMPOSITION TILE FLOORING.....	6
46	096813	TILE CARPETING.....	6
47	099123	INTERIOR PAINTING.....	6
48			
49			

WINDOWS REPLACEMENT - LINDENWOLD HIGH SCHOOL  
REGAN YOUNG ENGLAND BUTERA, PC PROJECT #5773D

1	<b>DIVISION 10 – SPECIALTIES</b>	
2		
3	101423 FIELD-APPLIED VINYL SIGNAGE .....	3
4	101423.16 ROOM IDENTIFICATION PANEL SIGNAGE.....	5
5		
6	<b>DIVISION 12 – FURNISHINGS</b>	
7		
8	123661.16 SOLID SURFACING WINDOWSILLS .....	3
9		
10		
11	END OF SECTION 000010	

## SECTION 081416 - FLUSH WOOD DOORS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Five-ply flush wood veneer-faced doors for transparent finish.
  - 2. Factory finishing flush wood doors.
  - 3. Factory fitting flush wood doors to frames and factory machining for hardware.

#### 1.3 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product, including the following:
  - 1. Door core materials and construction.
  - 2. Door edge construction
  - 3. Door face type and characteristics.
  - 4. Door trim for openings.
  - 5. Door frame construction.
  - 6. Factory-machining criteria.
  - 7. Factory-finishing specifications.
- B. Shop Drawings: Indicate location, size, and hand of each door; elevation of each type of door; construction details not covered in Product Data; and the following:
  - 1. Door schedule indicating door and frame location, type, size, fire protection rating, and swing.
  - 2. Door elevations, dimension and locations of hardware, lite and louver cutouts, and glazing thicknesses.
  - 3. Details of frame for each frame type, including dimensions and profile.
  - 4. Details of electrical raceway and preparation for electrified hardware, access control systems, and security systems.
  - 5. Dimensions and locations of blocking for hardware attachment.
  - 6. Dimensions and locations of mortises and holes for hardware.

7. Clearances and undercuts.
8. Requirements for veneer matching.
9. Doors to be factory finished and application requirements.

C. Samples for Initial Selection: For factory-finished doors.

D. Samples for Verification:

1. Factory finishes applied to actual door face materials, approximately 8 by 10 inches (200 by 250 mm), for each material and finish. For each wood species and transparent finish, provide set of three Samples showing typical range of color and grain to be expected in finished Work.
2. Corner sections of doors, approximately 8 by 10 inches (200 by 250 mm), with door faces and edges representing actual materials to be used.
3. Frames for light openings, 6 inches (150 mm) long, for each material, type, and finish required.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.
- B. Sample Warranty: For special warranty.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Special warranties.
- B. Record Documents: For fire-rated doors, list of door numbers and applicable room name and number to which door accesses.

#### 1.7 QUALITY ASSURANCE

- A. Manufacturer's Certification: Licensed participant in AWI's Quality Certification Program.

#### 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of referenced standard and manufacturer's written instructions.
- B. Package doors individually in cardboard cartons, and wrap bundles of doors in plastic sheeting.
- C. Mark each door on top and bottom rail with opening number used on Shop Drawings.

#### 1.9 FIELD CONDITIONS

- A. Environmental Limitations: Do not deliver or install doors until spaces are enclosed and weathertight, wet-work in spaces is complete and dry, and HVAC system is operating and

maintaining temperature and relative humidity at levels designed for building occupants for the remainder of construction period.

#### 1.10 WARRANTY

A. Special Warranty: Manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.

1. Failures include, but are not limited to, the following:
  - a. Delamination of veneer.
  - b. Warping (bow, cup, or twist) more than 1/4 inch (6.4 mm) in a 42-by-84-inch (1067-by-2134-mm) section.
  - c. Telegraphing of core construction in face veneers exceeding 0.01 inch in a 3-inch (0.25 mm in a 76.2-mm) span.
2. Warranty shall also include installation and finishing that may be required due to repair or replacement of defective doors.
3. Warranty Period for Solid-Core Interior Doors: Life of installation.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

A. Source Limitations: Obtain flush wood doors from single manufacturer.

#### 2.2 SEVEN-PLY FLUSH WOOD VENEER-FACED DOORS FOR TRANSPARENT FINISH

A. Interior Doors:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. ABS-American Building Supply, Inc.
  - b. General Veneer Manufacturing Co.
  - c. Haley Brothers, Inc.
  - d. Lambton Doors.
  - e. Oregon Door.
  - f. Vancouver Door Company.
  - g. Approved equal.
2. Performance Grade: ANSI/WDMA I.S. 1A Heavy Duty.
3. Architectural Woodwork Standards Grade: Premium.

4. Faces: Single-ply wood veneer not less than 1/50 inch (0.508 mm) thick or two-ply wood panel with wood veneer not less than 1/50 inch (0.508 mm) thick.
  - a. Species: Red oak.
  - b. Cut: Rotary cut.
  - c. Match between Veneer Leaves: Book match.
  - d. Assembly of Veneer Leaves on Door Faces: Center-balance match.
  - e. Pair and Set Match: Provide for doors hung in same opening or separated only by mullions.
5. Exposed Vertical and Top Edges: Same species as faces or a compatible species - Architectural Woodwork Standards edge Type A.
  - a. Mineral-Core Doors: At hinge stiles, provide laminated-edge construction with improved screw-holding capability and split resistance. Comply with specified requirements for exposed edges.
    - 1) Screw-Holding Capability: 550 lbf (2440 N) in accordance with WDMA T.M. 10.

## 2.3 FABRICATION

- A. Factory fit doors to suit frame-opening sizes indicated.
  1. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.
- B. Factory machine doors for hardware that is not surface applied.
  1. Locate hardware to comply with DHI-WDHS-3.
  2. Comply with final hardware schedules, door frame Shop Drawings, ANSI/BHMA-156.115-W, and hardware templates.
  3. Coordinate with hardware mortises in metal frames, to verify dimensions and alignment before factory machining.
  4. For doors scheduled to receive electrified locksets, provide factory-installed raceway and wiring to accommodate specified hardware.
  5. Metal Astragals: Factory machine astragals and formed-steel edges for hardware for pairs of fire-rated doors.
- C. Openings: Factory cut and trim openings through doors.
  1. Light Openings: Trim openings with moldings of material and profile indicated.
  2. Glazing: Factory install glazing in doors indicated to be factory finished. Comply with applicable requirements in Section 088000 "Glazing" and as shown on the drawings.

## 2.4 FACTORY FINISHING

- A. Comply with referenced quality standard for factory finishing.

WINDOWS REPLACEMENT - LINDENWOLD HIGH SCHOOL  
REGAN YOUNG ENGLAND BUTERA, PC PROJECT #5773D

1. Complete fabrication, including fitting doors for openings and machining for hardware that is not surface applied, before finishing.
  2. Finish faces, all four edges, edges of cutouts, and mortises.
  3. Stains and fillers may be omitted on top and bottom edges, edges of cutouts, and mortises.
- B. Factory finish doors.
- C. Transparent Finish:
1. Architectural Woodwork Standards Grade: Premium.
  2. Finish: ANSI/WDMA I.S. 1A TR-6 Catalyzed Polyurethane.
  3. Staining: As selected by Architect from manufacturer's full range.
  4. Effect: Semifilled finish, produced by applying an additional finish coat to partially fill the wood pores.
  5. Sheen: Satin.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine doors and installed door frames, with Installer present, before hanging doors.
1. Verify that installed frames comply with indicated requirements for type, size, location, and swing characteristics and have been installed with level heads and plumb jambs.
  2. Reject doors with defects.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Hardware: For installation, see Section 087100 "Door Hardware."
- B. Install doors to comply with manufacturer's written instructions and referenced quality standard, and as indicated.
- C. Install frames level, plumb, true, and straight.
1. Shim as required with concealed shims. Install level and plumb to a tolerance of 1/8 inch in 96 inches (3.2 mm in 2400 mm).
  2. Anchor frames to anchors or blocking built in or directly attached to substrates.
    - a. Secure with countersunk, concealed fasteners and blind nailing.
    - b. Use fine finishing nails or finishing screws for exposed fastening, countersunk and filled flush with woodwork.

- 1) For factory-finished items, use filler matching finish of items being installed.

D. Factory-Fitted Doors: Align in frames for uniform clearance at each edge.

### 3.3 FIELD QUALITY CONTROL

- A. Repair or remove and replace installations where inspections indicate that they do not comply with specified requirements.
- B. Reinspect repaired or replaced installations to determine if replaced or repaired door assembly installations comply with specified requirements.

### 3.4 ADJUSTING

- A. Operation: Rehang or replace doors that do not swing or operate freely.
- B. Finished Doors: Replace doors that are damaged or that do not comply with requirements. Doors may be repaired or refinished if Work complies with requirements and shows no evidence of repair or refinishing.

END OF SECTION 081416

## SECTION 087100 - DOOR HARDWARE

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. This Section includes commercial door hardware for the following:
  - 1. Swinging doors.
- B. Door hardware includes, but is not necessarily limited to, the following:
  - 1. Mechanical door hardware.
  - 2. Cylinders specified for doors in other sections.
- C. Related Sections:
  - 1. Division 08 Section "Hollow Metal Doors and Frames".
  - 2. Division 08 Section "Flush Wood Doors".
- D. Codes and References: Comply with the version year adopted by the Authority Having Jurisdiction.
  - 1. ANSI A117.1 - Accessible and Usable Buildings and Facilities.
  - 2. ICC/IBC - International Building Code.
  - 3. NFPA 70 - National Electrical Code.
  - 4. NFPA 80 - Fire Doors and Windows.
  - 5. NFPA 101 - Life Safety Code.
  - 6. NFPA 105 - Installation of Smoke Door Assemblies.
  - 7. State Building Codes, Local Amendments.
- E. Standards: All hardware specified herein shall comply with the following industry standards as applicable. Any undated reference to a standard shall be interpreted as referring to the latest edition of that standard:
  - 1. ANSI/BHMA Certified Product Standards - A156 Series.
  - 2. UL10C - Positive Pressure Fire Tests of Door Assemblies.
  - 3. ANSI/UL 294 - Access Control System Units.
  - 4. UL 305 - Panic Hardware.
  - 5. ANSI/UL 437- Key Locks.

### 1.3 SUBMITTALS

- A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.
- B. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing, fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final Door Hardware Schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
  - 1. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule."
  - 2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening. Organize door hardware sets in same order as in the Door Hardware Sets at the end of Part 3. Submittals that do not follow the same format and order as the Door Hardware Sets will be rejected and subject to resubmission.
  - 3. Content: Include the following information:
    - a. Type, style, function, size, label, hand, and finish of each door hardware item.
    - b. Manufacturer of each item.
    - c. Fastenings and other pertinent information.
    - d. Location of door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
    - e. Explanation of abbreviations, symbols, and codes contained in schedule.
    - f. Mounting locations for door hardware.
    - g. Door and frame sizes and materials.
    - h. Warranty information for each product.
  - 4. Submittal Sequence: Submit the final Door Hardware Schedule at earliest possible date, particularly where approval of the Door Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the Door Hardware Schedule.
- C. Keying Schedule: After a keying meeting with the owner has taken place prepare a separate keying schedule detailing final instructions. Submit the keying schedule in electronic format. Include keying system explanation, door numbers, key set symbols, hardware set numbers and special instructions. Owner must approve submitted keying schedule prior to the ordering of permanent cylinders/cores.
- D. Informational Submittals:
  - 1. Product Test Reports: Indicating compliance with cycle testing requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified independent testing agency.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Operating and Maintenance Manuals: Provide manufacturers operating and maintenance manuals for each item comprising the complete door hardware installation in quantity as required in Division 01, Closeout Procedures.
- B. Project Record Documents: Provide record documentation of as-built door hardware sets in digital format (.pdf, .docx, .xlsx, .csv) and as required in Division 01, Project Record Documents.

#### 1.5 QUALITY ASSURANCE

- A. Manufacturers Qualifications: Engage qualified manufacturers with a minimum 5 years of documented experience in producing hardware and equipment similar to that indicated for this Project and that have a proven record of successful in-service performance.
- B. Certified Products: Where specified, products must maintain a current listing in the Builders Hardware Manufacturers Association (BHMA) Certified Products Directory (CPD).
- C. Installer Qualifications: A minimum 3 years documented experience installing both standard and electrified door hardware similar in material, design, and extent to that indicated for this Project and whose work has resulted in construction with a record of successful in-service performance.
- D. Door Hardware Supplier Qualifications: Experienced commercial door hardware distributors with a minimum 5 years documented experience supplying both mechanical and electromechanical hardware installations comparable in material, design, and extent to that indicated for this Project. Supplier recognized as a factory direct distributor by the manufacturers of the primary materials with a warehousing facility in Project's vicinity. Supplier to have on staff a certified Architectural Hardware Consultant (AHC) available during the course of the Work to consult with Contractor, Architect, and Owner concerning both standard and electromechanical door hardware and keying.
- E. Source Limitations: Obtain each type and variety of door hardware specified in this section from a single source unless otherwise indicated.
  - 1. Electrified modifications or enhancements made to a source manufacturer's product line by a secondary or third party source will not be accepted.
- F. Each unit to bear third party permanent label indicating compliance with the referenced testing standards.
- G. Keying Conference: Conduct conference to comply with requirements in Division 01 Section "Project Meetings." Keying conference to incorporate the following criteria into the final keying schedule document:
  - 1. Function of building, purpose of each area and degree of security required.
  - 2. Plans for existing and future key system expansion.
  - 3. Requirements for key control storage and software.

4. Installation of permanent keys, cylinder cores and software.
  5. Address and requirements for delivery of keys.
- H. Pre-Submittal Conference: Conduct coordination conference in compliance with requirements in Division 01 Section "Project Meetings" with attendance by representatives of Supplier(s), Installer(s), and Contractor(s) to review proper methods and the procedures for receiving, handling, and installing door hardware.
1. Prior to installation of door hardware, conduct a project specific training meeting to instruct the installing contractors' personnel on the proper installation and adjustment of their respective products. Product training to be attended by installers of door hardware (including electromechanical hardware) for aluminum, hollow metal and wood doors. Training will include the use of installation manuals, hardware schedules, templates and physical product samples as required.
  2. Inspect and discuss electrical roughing-in, power supply connections, and other preparatory work performed by other trades.
  3. Review sequence of operation narratives for each unique access controlled opening.
  4. Review and finalize construction schedule and verify availability of materials.
  5. Review the required inspecting, testing, commissioning, and demonstration procedures
- I. At completion of installation, provide written documentation that components were applied according to manufacturer's instructions and recommendations and according to approved schedule.

#### 1.6 DELIVERY, STORAGE AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
- B. Tag each item or package separately with identification related to the final Door Hardware Schedule, and include basic installation instructions with each item or package.
- C. Deliver, as applicable, permanent keys, cylinders, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner shall be established at the "Keying Conference".

#### 1.7 COORDINATION

- A. Templates: Obtain and distribute to the parties involved templates for doors, frames, and other work specified to be factory prepared for installing standard and electrified hardware. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing hardware to comply with indicated requirements.
- B. Door and Frame Preparation: Doors and corresponding frames are to be prepared, reinforced and pre-wired (if applicable) to receive the installation of the specified electrified, monitoring, signaling and access control system hardware without additional in-field modifications.

## 1.8 WARRANTY

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article shall not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by Contractor under requirements of the Contract Documents.
- B. Warranty Period: Written warranty, executed by manufacturer(s), agreeing to repair or replace components of standard and electrified door hardware that fails in materials or workmanship within specified warranty period after final acceptance by the Owner. Failures include, but are not limited to, the following:
  - 1. Structural failures including excessive deflection, cracking, or breakage.
  - 2. Faulty operation of the hardware.
  - 3. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
  - 4. Electrical component defects and failures within the systems operation.
- C. Warranty Period: Unless otherwise indicated, warranty shall be one year from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 BUTT HINGES

- A. Hinges: ANSI/BHMA A156.1 butt hinges with number of hinge knuckles and other options as specified in the Door Hardware Sets.
  - 1. Quantity: Provide the following hinge quantity:
    - a. Two Hinges: For doors with heights up to 60 inches.
    - b. Three Hinges: For doors with heights 61 to 90 inches.
    - c. Four Hinges: For doors with heights 91 to 120 inches.
    - d. For doors with heights more than 120 inches, provide 4 hinges, plus 1 hinge for every 30 inches of door height greater than 120 inches.
  - 2. Hinge Size: Provide the following, unless otherwise indicated, with hinge widths sized for door thickness and clearances required:
    - a. Widths up to 3'0": 4-1/2" standard or heavy weight as specified.
    - b. Sizes from 3'1" to 4'0": 5" standard or heavy weight as specified.
  - 3. Hinge Weight and Base Material: Unless otherwise indicated, provide the following:
    - a. Exterior Doors: Heavy weight, non-ferrous, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate standard weight.
    - b. Interior Doors: Standard weight, steel, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate heavy weight.
  - 4. Hinge Options: Comply with the following:

- a. Non-removable Pins: With the exception of electric through wire hinges, provide set screw in hinge barrel that, when tightened into a groove in hinge pin, prevents removal of pin while door is closed; for all out-swinging lockable doors.
- 5. Manufacturers:
  - a. Ives (IV) - 5BB Series, 5-knuckle.
  - b. McKinney (MK) - TA/T4A Series, 5-knuckle.
  - c. dormakaba BEST (ST) - F/FBB Series, 5-knuckle.
  - d. Approved equal.

## 2.2 CYLINDERS AND KEYING

- A. General: Cylinder manufacturer to have minimum (10) years experience designing secured master key systems and have on record a published security keying system policy.
  - 1. Manufacturers:
    - a. Corbin Russwin Hardware (RU).
    - b. dormakaba BEST (BE).
    - c. Sargent Manufacturing (SA).
    - d. Approved equal.
- B. Cylinder Types: Original manufacturer cylinders able to supply the following cylinder formats and types:
  - 1. Threaded mortise cylinders with rings and cams to suit hardware application.
  - 2. Rim cylinders with back plate, flat-type vertical or horizontal tailpiece, and raised trim ring.
  - 3. Bored or cylindrical lock cylinders with tailpieces as required to suit locks.
  - 4. Tubular deadlocks and other auxiliary locks.
  - 5. Mortise and rim cylinder collars to be solid and recessed to allow the cylinder face to be flush and be free spinning with matching finishes.
  - 6. Keyway: Match Facility Standard.
- C. Keying System: Each type of lock and cylinders to be factory keyed.
  - 1. Supplier shall conduct a "Keying Conference" to define and document keying system instructions and requirements.
  - 2. Furnish factory cut, nickel-silver large bow permanently inscribed with a visual key control number as directed by Owner.
  - 3. Existing System: Field verify and key cylinders to match Owner's existing system.
- D. Key Quantity: Provide the following minimum number of keys:
  - 1. Change Keys per Cylinder: Two (2)
  - 2. Master Keys (per Master Key Level/Group): Five (5).
  - 3. Construction Keys (where required): Ten (10).

- E. Construction Keying: Provide construction master keyed cylinders.
- F. Key Registration List (Bitting List):
  - 1. Provide keying transcript list to Owner's representative in the proper format for importing into key control software.
  - 2. Provide transcript list in writing or electronic file as directed by the Owner.

## 2.3 KEY CONTROL

## 2.4 MORTISE LOCKS AND LATCHING DEVICES

- A. Mortise Locksets, Grade 1 (Heavy Duty): Provide ANSI/BHMA A156.13, Series 1000, Operational Grade 1 Certified Products Directory (CPD) listed mortise locksets. Listed manufacturers shall meet all functions and features as specified herein.
  - 1. Manufacturers:
    - a. Corbin Russwin Hardware (RU) - ML2000 Series.
    - b. dormakaba BEST (BE) - 45H Series.
    - c. Sargent Manufacturing (SA) - 8200 Series.
    - d. Approved equal.

## 2.5 LOCK AND LATCH STRIKES

- A. Strikes: Provide manufacturer's standard strike with strike box for each latch or lock bolt, with curved lip extended to protect frame, finished to match door hardware set, unless otherwise indicated, and as follows:
  - 1. Flat-Lip Strikes: For locks with three-piece antifriction latchbolts, as recommended by manufacturer.
  - 2. Extra-Long-Lip Strikes: For locks used on frames with applied wood casing trim.
  - 3. Aluminum-Frame Strike Box: Provide manufacturer's special strike box fabricated for aluminum framing.
  - 4. Double-lipped strikes: For locks at double acting doors. Furnish with retractable stop for rescue hardware applications.
- B. Standards: Comply with the following:
  - 1. Strikes for Mortise Locks and Latches: BHMA A156.13.
  - 2. Strikes for Bored Locks and Latches: BHMA A156.2.
  - 3. Strikes for Auxiliary Deadlocks: BHMA A156.36.
  - 4. Dustproof Strikes: BHMA A156.16.

## 2.6 SURFACE DOOR CLOSERS

- A. All door closers specified herein shall meet or exceed the following criteria:

1. General: Door closers to be from one manufacturer, matching in design and style, with the same type door preparations and templates regardless of application or spring size. Closers to be non-handed with full sized covers.
  2. Standards: Closers to comply with UL-10C for Positive Pressure Fire Test and be U.L. listed for use of fire rated doors.
  3. Size of Units: Comply with manufacturer's written recommendations for sizing of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Where closers are indicated for doors required to be accessible to the Americans with Disabilities Act, provide units complying with ANSI ICC/A117.1.
  4. Closer Arms: Provide heavy duty, forged steel closer arms unless otherwise indicated in Hardware Sets.
  5. Closers shall not be installed on exterior or corridor side of doors; where possible install closers on door for optimum aesthetics.
  6. Closer Accessories: Provide door closer accessories including custom templates, special mounting brackets, spacers and drop plates as required for proper installation. Provide through-bolt and security type fasteners as specified in the hardware sets.
- B. Door Closers, Surface Mounted (Heavy Duty): ANSI/BHMA A156.4, Grade 1 Certified Products Directory (CPD) listed surface mounted, heavy duty door closers with complete spring power adjustment, sizes 1 thru 6; and fully operational adjustable according to door size, frequency of use, and opening force. Closers to be rack and pinion type, one piece cast iron or aluminum alloy body construction, with adjustable backcheck and separate non-critical valves for closing sweep and latch speed control. Provide non-handed units standard.
1. Heavy duty surface mounted door closers shall have a 30-year warranty.
  2. Manufacturers:
    - a. Corbin Russwin Hardware (RU) - DC6000 Series.
    - b. Norton Rixson (NO) - 7500 Series.
    - c. Sargent Manufacturing (SA) - 351 Series.
    - d. Approved equal.

## 2.7 ELECTROMECHANICAL DOOR OPERATORS

- A. Electromechanical Door Operators (High Traffic): Provide ANSI/BHMA A156.19 Certified Products Directory (CPD) listed low energy operators that are UL325/991 and UL10C certified and comply with requirements for the Americans with Disabilities Act (ADA). Operators shall accommodate openings up to 250 pounds and 48" wide.
1. Provide operators with features as follows:
    - a. Non-handed with push and pull side mounting.
    - b. Activation by push button, hands-free or radio frequency devices.
    - c. Adjustable opening force and closing power.
    - d. Two-year limited warranty.
    - e. Wi-Fi interface where the operator is a secure, password protected WiFi hot spot with no connection to building's IT required.
      - 1) Simple setup with no app required.

- 2) View status and make adjustments without removing the cover.
  - 3) Built-in logic to support single use restroom applications with no external relay boards, logic modules, position switches required.
  - f. Mounting backplate to simplify and speed up installation.
  - g. Integration with access control systems.
2. Operators shall have the following functionality:
- a. Adjustable Hold Open: Amount of time a door will stay in the full open position after an activation.
  - b. Blow Open for Smoke Ventilation: Door opens when signal is received from alarm system allowing air or smoke to flow through opening. Door will stay open until signal from alarm system is stopped.
  - c. Emergency Interface Relay: Door closes and ignores any activation input until signal is discontinued.
  - d. Infinite Hold Open: Door will hold open at set position until power is turned off.
  - e. Latch Assist: At closed position, after an activation, the door is pulled in. After the door has closed, the door is pulled in to assist with latch release/engagement.
  - f. Obstruction Detection: Door closes if it hits an obstruction while opening; door will reverse to open position if it hits an obstruction while closing. Door will stop once it hits an obstruction and will rest against the obstruction until removed.
  - g. Open Delay: Delays operator opening for locking hardware.
  - h. Outside Wall Switch Disable: When contact is closed, outside wall switch is disabled.
  - i. Power Assist: Senses the door is being opened manually and applies small amount of power to assist the user in opening the door with force less than 5 lbs. The door opens only as far as it is moved manually, then closes once released.
  - j. Power Close: Additional force to assist door closing between 7° and 2°.
  - k. Presence Detector Input: Input for external sensor to detect presence at door open or close position only.
  - l. Push & Go: As the door is manually opened, the operator "senses" movement and opens door to the full-open position.
  - m. Selector Mode Switch: Off disables the signal inputs unless Blow Open is activated, on activates the signal inputs, hold open activates the unit (unless Blow Closed is activated) to the hold open position.
  - n. Vestibule Delay: When the wall switch is pressed, first door in vestibule will open. Second door will open once vestibule door delay has expired. Delay is adjustable.
  - o. Executive Mode Feature: When the door receives an activation signal it opens and remains open until either a second signal is received, or the door is manually moved in closing direction.
3. Manufacturers:
- a. Norton Rixson (NO) - 6300 Series.
  - b. Approved equal.

## 2.8 ARCHITECTURAL TRIM

### A. Door Protective Trim

1. General: Door protective trim units to be of type and design as specified below or in the Hardware Sets.
2. Size: Fabricate protection plates (kick, armor, or mop) not more than 2" less than door width (LDW) on stop side of single doors and 1" LDW on stop side of pairs of doors, and not more than 1" less than door width on pull side. Coordinate and provide proper width and height as required where conflicting hardware dictates. Height to be as specified in the Hardware Sets.
3. Where plates are applied to fire rated doors with the top of the plate more than 16" above the bottom of the door, provide plates complying with NFPA 80. Consult manufacturer's catalog and template book for specific requirements for size and applications.
4. Protection Plates: ANSI/BHMA A156.6 protection plates (kick, armor, or mop), fabricated from the following:
  - a. Stainless Steel: 300 grade, 050-inch thick.
5. Options and fasteners: Provide manufacturer's designated fastener type as specified in the Hardware Sets. Provide countersunk screw holes.
6. Manufacturers:
  - a. Rockwood (RO).

## 2.9 DOOR STOPS AND HOLDERS

- A. General: Door stops and holders to be of type and design as specified below or in the Hardware Sets.
- B. Door Stops and Bumpers: ANSI/BHMA A156.16, Grade 1 door stops and wall bumpers. Provide wall bumpers, either convex or concave types with anchorage as indicated, unless floor or other types of door stops are specified in Hardware Sets. Do not mount floor stops where they will impede traffic. Where floor or wall bumpers are not appropriate, provide overhead type stops and holders.
  1. Manufacturers:
    - a. Ives (IV).
    - b. Rockwood (RO).
    - c. Trimco (TC).
    - d. Approved equal.

## 2.10 ARCHITECTURAL SEALS

- A. General: Thresholds, weatherstripping, and gasket seals to be of type and design as specified below or in the Hardware Sets. Provide continuous weatherstrip gasketing on exterior doors and provide smoke, light, or sound gasketing on interior doors where indicated. At exterior applications provide non-corrosive fasteners and elsewhere where indicated.
- B. Smoke Labeled Gasketing: Assemblies complying with NFPA 105 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for smoke control ratings indicated, based on testing according to UL 1784.

1. Provide smoke labeled perimeter gasketing at all smoke labeled openings.
- C. Fire Labeled Gasketing: Assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to UL-10C.
  1. Provide intumescent seals as indicated to meet UL10C Standard for Positive Pressure Fire Tests of Door Assemblies, and NFPA 252, Standard Methods of Fire Tests of Door Assemblies.
- D. Sound-Rated Gasketing: Assemblies that are listed and labeled by a testing and inspecting agency, for sound ratings indicated.
- E. Replaceable Seal Strips: Provide only those units where resilient or flexible seal strips are easily replaceable and readily available from stocks maintained by manufacturer.
- F. Manufacturers:
  1. National Guard Products (NG).
  2. Pemko (PE).
  3. Zero (ZE).
  4. Approved equal.

## 2.11 FABRICATION

- A. Fasteners: Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. Provide screws according to manufacturers recognized installation standards for application intended.

## 2.12 FINISHES

- A. Standard: Designations used in the Hardware Sets and elsewhere indicate hardware finishes complying with ANSI/BHMA A156.18, including coordination with traditional U.S. finishes indicated by certain manufacturers for their products.
- B. Provide quality of finish, including thickness of plating or coating (if any), composition, hardness, and other qualities complying with manufacturer's standards, but in no case less than specified by referenced standards for the applicable units of hardware
- C. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine scheduled openings, with Installer present, for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Notify architect of any discrepancies or conflicts between the door schedule, door types, drawings and scheduled hardware. Proceed only after such discrepancies or conflicts have been resolved in writing.

#### 3.2 PREPARATION

- A. Hollow Metal Doors and Frames: Comply with ANSI/DHI A115 series.
- B. Wood Doors: Comply with ANSI/DHI A115-W series.

#### 3.3 INSTALLATION

- A. Install each item of mechanical and electromechanical hardware and access control equipment to comply with manufacturer's written instructions and according to specifications.
  - 1. Installers are to be trained and certified by the manufacturer on the proper installation and adjustment of fire, life safety, and security products including: hanging devices; locking devices; closing devices; and seals.
- B. Mounting Heights: Mount door hardware units at heights indicated in following applicable publications, unless specifically indicated or required to comply with governing regulations:
  - 1. Standard Steel Doors and Frames: DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
  - 2. DHI TDH-007-20: Installation Guide for Doors and Hardware.
  - 3. Where indicated to comply with accessibility requirements, comply with ANSI A117.1 "Accessibility Guidelines for Buildings and Facilities."
  - 4. Provide blocking in drywall partitions where wall stops or other wall mounted hardware is located.
- C. Retrofitting: Install door hardware to comply with manufacturer's published templates and written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work specified in Division 9 Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.
- D. Push Plates and Door Pulls: When through-bolt fasteners are in the same location as a push plate, countersink the fasteners flush with the door face allowing the push plate to sit flat against the door.

- E. Thresholds: Set thresholds for exterior and acoustical doors in full bed of sealant complying with requirements specified in Division 7 Section "Joint Sealants."
- F. Storage: Provide a secure lock up for hardware delivered to the project but not yet installed. Control the handling and installation of hardware items so that the completion of the work will not be delayed by hardware losses before and after installation.

### 3.4 FIELD QUALITY CONTROL

- A. Field Inspection (Punch Report): Reference Division 01 Sections "Closeout Procedures". Produce project punch report for each installed door opening indicating compliance with approved submittals and verification hardware is properly installed, operating and adjusted. Include list of items to be completed and corrected, indicating the reasons or deficiencies causing the Work to be incomplete or rejected.
  - 1. Organization of List: Include separate Door Opening and Deficiencies and Corrective Action Lists organized by Mark, Opening Remarks and Comments, and related Opening Images and Video Recordings.

### 3.5 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

### 3.6 CLEANING AND PROTECTION

- A. Protect all hardware stored on construction site in a covered and dry place. Protect exposed hardware installed on doors during the construction phase. Install any and all hardware at the latest possible time frame.
- B. Clean adjacent surfaces soiled by door hardware installation.
- C. Clean operating items as necessary to restore proper finish. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of owner occupancy.

### 3.7 DEMONSTRATION

- A. Instruct Owner's maintenance personnel to adjust, operate, and maintain mechanical and electromechanical door hardware.

### 3.8 DOOR HARDWARE SETS

- A. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with

corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.

1. Quantities listed are for each pair of doors, or for each single door.
2. The supplier is responsible for handing and sizing all products.
3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.
4. At existing openings with new hardware the supplier shall field inspect existing conditions prior to the submittal stage to verify the specified hardware will work as required. Provide alternate solutions and proposals as needed.

B. Refer to Section 080671, Door Hardware Sets, for hardware sets.

END OF SECTION 087100

## SECTION 090190.52 - MAINTENANCE REPAINTING

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes maintenance repainting as follows:
  - 1. Removing existing paint and wallpaper.
  - 2. Patching substrates.

#### 1.3 RELATED SECTIONS

- A. Section 099123, "Interior Painting" for repainting requirements.

#### 1.4 DEFINITIONS

- A. Gloss Level 1: Not more than 5 units at 60 degrees and 10 units at 85 degrees, according to ASTM D 523.
- B. Gloss Level 2: Not more than 10 units at 60 degrees and 10 to 35 units at 85 degrees, according to ASTM D 523.
- C. Gloss Level 3: 10 to 25 units at 60 degrees and 10 to 35 units at 85 degrees, according to ASTM D 523.
- D. Gloss Level 4: 20 to 35 units at 60 degrees and not less than 35 units at 85 degrees, according to ASTM D 523.
- E. Gloss Level 5: 35 to 70 units at 60 degrees, according to ASTM D 523.
- F. Gloss Level 6: 70 to 85 units at 60 degrees, according to ASTM D 523.
- G. Gloss Level 7: More than 85 units at 60 degrees, according to ASTM D 523.
- H. Low-Pressure Spray: 100 to 400 psi (690 to 2750 kPa); 4 to 6 gpm (0.25 to 0.4 L/s).
- I. Medium-Pressure Spray: 400 to 800 psi (2750 to 5510 kPa); 4 to 6 gpm (0.25 to 0.4 L/s).

## 1.5 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.

## 1.6 SEQUENCING AND SCHEDULING

- A. Perform maintenance repainting in the following sequence, which includes work specified in this and other Sections:
  - 1. Dismantle existing surface-mounted objects and hardware except items indicated to remain in place. Tag items with location identification and protect.
  - 2. Verify that temporary protections have been installed.
  - 3. Examine condition of surfaces to be painted.
  - 4. Remove existing paint to the degree required for each substrate and surface condition of existing paint.
  - 5. Apply paint system.
  - 6. Reinstall dismantled surface-mounted objects and hardware unless otherwise indicated.

## 1.7 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include recommendations for product application and use.
  - 2. Include test data substantiating that products comply with requirements.
- B. Samples: For each type of paint system and each pattern, color, and gloss; minimum 6 inches (150 mm) long in least dimension, but not less than whole pattern.
  - 1. Include stepped Samples defining each separate coat, including fillers and primers. Resubmit until each required sheen, color, and texture is achieved.
  - 2. Include a list of materials for each coat of each Sample.
  - 3. Label each Sample for location and application.
  - 4. Sample Size:
    - a. Painted Surfaces: 4-by-8-inch (100-by-200-mm). Samples for each color and material, on hardboard.
- C. Product List: For each paint product indicated, include the following:
  - 1. Cross-reference to paint system and locations of application areas. Use same designations indicated on Drawings and in schedules.
  - 2. Printout of current "MPI Approved Products List" for each MPI-product category specified in paint systems, with the proposed product highlighted.
  - 3. VOC content.

1.8 INFORMATIONAL SUBMITTALS

- A. Color Matching Certificate: For computer-matched colors.
- B. Preconstruction Test Reports: For cleaning materials, paint removers and paint coatings and systems.

1.9 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra paint materials, from the same production run, that match products applied and that are packaged with protective covering for storage and identified with labels describing contents, including material, finish, source, and location on building.
  - 1. Quantity: Furnish Owner with an additional 5 percent, but not less than 1 gal. (3.8 L) of each material and color applied.

1.10 QUALITY ASSURANCE

- A. Color Matching: Custom computer-match paint colors.
- B. Mockups: Prepare mockups of maintenance repainting processes for each type of coating system and substrate indicated and each color and finish required to demonstrate aesthetic effects and to set quality standards for materials and execution. Duplicate appearance of approved Sample submittals.
  - 1. Locate mockups on existing surfaces where directed by Architect.
  - 2. Surface-Preparation Mockups: On existing surfaces using applicable specified methods of cleaning and other surface preparation, provide mockup sample of at least 100 sq. ft. (9 sq. m).
  - 3. Coating Mockups: Two surfaces of at least 100 sq. ft. (9 sq. m) to represent surfaces and conditions for application of each type of coating system under same conditions as the completed Work.
  - 4. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
  - 5. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.11 PRECONSTRUCTION TESTING

- A. Preconstruction Testing Service: Engage a qualified testing agency to perform preconstruction testing of cleaning materials, and compatibility of paint coatings and systems for each type of painted surface.
  - 1. Use test areas as indicated and representative of proposed materials and existing construction.

2. Propose changes to materials and methods to suit Project.

#### 1.12 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).
  1. Maintain containers in clean condition, free of foreign materials and residue.
  2. Remove rags and waste daily.

#### 1.13 FIELD CONDITIONS

- A. Weather Limitations: Proceed with maintenance repainting only when existing and forecasted weather conditions are within the environmental limits set by each manufacturer's written instructions and specified requirements.
- B. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F (10 and 35 deg C).
- C. Do not apply paint in snow, rain, fog, or mist; when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.
  1. Painting may continue during inclement weather if surfaces and areas to be painted are enclosed and heated within temperature limits specified by manufacturer for surface preparation and during paint application and drying periods.

### PART 2 - PRODUCTS

#### 2.1 PREPARATORY CLEANING MATERIALS

- A. Water: Potable.
- B. Detergent Solution: Solution prepared by mixing 2 cups (0.5 L) of tetrasodium pyrophosphate (TSPP), 1/2 cup (125 mL) of laundry detergent that contains no ammonia, 5 quarts (5 L) of 5 percent sodium hypochlorite bleach, and 15 quarts (15 L) of warm water for every 5 gal. (20 L) of solution required.
- C. Mildewcide: Commercial proprietary mildewcide or a job-mixed solution prepared by mixing 1/3 cup (80 mL) of household detergent that contains no ammonia, 1 quart (1 L) of 5 percent sodium hypochlorite bleach, and 3 quarts (3 L) of warm water.
- D. Abrasives for Ferrous Metal Cleaning: Aluminum oxide paper, emery paper, fine steel wool, steel scrapers, and steel-wire brushes of various sizes.
- E. Rust Remover: Manufacturer's standard phosphoric acid-based gel formulation, also called "naval jelly," for removing corrosion from iron and steel.

## 2.2 PAINT REMOVERS

- A. Alkaline Paste Paint Remover: Manufacturer's standard alkaline paste or gel formulation for removing paint from masonry, stone, wood, plaster, or metal as required to suit Project; and containing no methylene chloride.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
    - a. American Building Restoration Products, Inc.
    - b. Diedrich Technologies, Inc.; a Hohmann & Barnard company.
    - c. EaCo Chem, Inc.
    - d. Approved equal.

## 2.3 PAINT, GENERAL

- A. Material Compatibility:
  - 1. Provide materials for use within each paint system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
  - 2. For each coat in a paint system, provide products recommended in writing by manufacturers of topcoat for use in paint system and on substrate indicated.
- B. Colors: As selected by Architect from full range of industry colors.

## 2.4 PAINT MATERIALS, GENERAL

- A. MPI Standards: Provide products that comply with MPI standards indicated and that are listed in its "MPI Approved Products List."
- B. Transition Coat: Paint manufacturer's recommended coating for use where a residual existing coating is incompatible with the paint system.

## 2.5 PATCHING MATERIALS

- A. Wood-Patching Compound: Two-part, epoxy-resin, wood-patching compound; knife-grade formulation as recommended in writing by manufacturer for type of wood repair indicated, tooling time required for the detail of work, and site conditions. Compound shall be designed for filling voids in damaged wood materials that have deteriorated from weathering and decay. Compound shall be capable of filling deep holes and spreading to feather edge.
- B. Metal-Patching Compound: Two-part, polyester-resin, metal-patching compound; knife-grade formulation as recommended in writing by manufacturer for type of metal repair indicated, tooling time required for the detail of work, and site conditions. Compound shall be produced

for filling metal that has deteriorated from corrosion. Filler shall be capable of filling deep holes and spreading to feather edge.

- C. Cementitious Patching Compounds: Cementitious patching compounds and repair materials specifically manufactured for filling cementitious substrates and for sanding or tooling prior to repainting; formulation as recommended in writing by manufacturer for type of cementitious substrate indicated, exposure to weather and traffic, the detail of work, and site conditions.
- D. Gypsum-Plaster Patching Compound: Finish coat plaster and bonding compound according to ASTM C 842 and manufacturer's written instructions.

### PART 3 - EXECUTION

#### 3.1 PROTECTION

- A. Comply with each manufacturer's written instructions for protecting building and other surfaces against damage from exposure to its products. Prevent chemical solutions from coming into contact with people, motor vehicles, landscaping, buildings, and other surfaces that could be harmed by such contact.
  - 1. Cover adjacent surfaces with materials that are proven to resist chemical solutions being used unless the solutions will not damage adjacent surfaces. Use protective materials that are UV resistant and waterproof. Apply masking agents to comply with manufacturer's written instructions. Do not apply liquid masking agent to painted or porous surfaces. When no longer needed, promptly remove masking to prevent adhesive staining.
  - 2. Do not apply chemical solutions during winds of sufficient force to spread them to unprotected surfaces.
  - 3. Neutralize and collect alkaline and acid wastes before disposal.
  - 4. Dispose of runoff from operations by legal means and in a manner that prevents soil erosion, undermining of paving and foundations, damage to landscaping, and water penetration into building interiors.

#### 3.2 MAINTENANCE REPAINTING, GENERAL

- A. Maintenance Repainting Appearance Standard: Completed work is to have a uniform appearance as viewed by Architect from building interior at 5 feet (1.5 m) away from painted surface and from building exterior at 20 feet (6 m) away from painted surface.
- B. Execution of the Work: In repainting surfaces, disturb them as minimally as possible and as follows:
  - 1. Remove failed coatings and corrosion and repaint.
  - 2. Verify that substrate surface conditions are suitable for repainting.
  - 3. Allow other trades to repair items in place before repainting.
  - 4. Do not paint existing school lockers in the corridors.

- C. Mechanical Abrasion: Where mechanical abrasion is needed for the work, use gentle methods, such as scraping and lightly hand sanding, that will not abrade softer substrates, reducing clarity of detail.
- D. Heat Processes: Do not use torches, heat guns, or heat plates.

### 3.3 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of painting work. Comply with paint manufacturer's written instructions for inspection.
- B. Maximum Moisture Content of Substrates: Do not begin application of coatings unless moisture content of exposed surface is below the maximum value recommended in writing by paint manufacturer and not greater than the following maximum values when measured with an electronic moisture meter appropriate to the substrate material:
  - 1. Concrete: 12 percent.
  - 2. Gypsum Board: 12 percent.
  - 3. Gypsum Plaster: 12 percent.
  - 4. Masonry (Clay and CMU): 12 percent.
  - 5. Portland Cement Plaster: 12 percent.
  - 6. Wood: 15 percent.
- C. Alkalinity: Do not begin application of coatings unless surface alkalinity is within range recommended in writing by paint manufacturer. Conduct alkali testing with litmus paper on exposed plaster, cementitious, and masonry surfaces.
- D. Verify suitability of substrates, including surface conditions and compatibility with existing finishes and primers.
  - 1. If existing surfaces cannot be prepared to an acceptable condition for proper finishing by using specified surface-preparation methods, notify Architect in writing.
- E. Begin coating application only after unsatisfactory conditions have been corrected and surfaces are dry.
  - 1. Beginning coating application constitutes Contractor's acceptance of substrates and conditions.

### 3.4 PREPARATORY CLEANING

- A. General: Use the gentlest, appropriate method necessary to clean surfaces in preparation for painting. Clean all surfaces, corners, contours, and interstices.
- B. Detergent Cleaning: Wash surfaces by hand using clean rags, sponges, and bristle brushes. Scrub surface with detergent solution and bristle brush until soil is thoroughly dislodged and

can be removed by rinsing. Use small brushes to remove soil from joints and crevices. Dip brush in solution often to ensure that adequate fresh detergent is used and that surface remains wet. Rinse with water applied by clean rags or sponges.

- C. Solvent Cleaning: Use solvent cleaning to remove oil, grease, smoke, tar, and asphalt from painted or unpainted surfaces before other preparation work. Wipe surfaces with solvent using clean rags and sponges. If necessary, spot-solvent cleaning may be employed just prior to commencement of paint application, provided enough time is allowed for complete evaporation. Use clean solvent and clean rags for the final wash to ensure that all foreign materials have been removed. Do not use solvents, including primer thinner and turpentine, that leave residue.
- D. Mildew: Clean off existing mildew, algae, moss, plant material, loose paint, grease, dirt, and other debris by scrubbing with bristle brush or sponge and detergent solution. Scrub mildewed areas with mildewcide. Rinse with water applied by clean rags or sponges.
- E. Chemical Rust Removal:
  - 1. Remove loose rust scale with specified abrasives for ferrous-metal cleaning.
  - 2. Apply rust remover with brushes or as recommended in writing by manufacturer.
  - 3. Allow rust remover to remain on surface for period recommended in writing by manufacturer or as determined by preconstruction testing. Do not allow extended dwell time.
  - 4. Wipe off residue with mineral spirits and either steel wool or soft rags, or clean with method recommended in writing by manufacturer to remove residue.
  - 5. Dry immediately with clean, soft cloths. Follow direction of grain in metal.
  - 6. Prime immediately to prevent rust. Do not touch cleaned metal surface until primed.

### 3.5 PAINT REMOVAL

- A. General: Remove paint where indicated. Where cleaning methods have been attempted and further removal of the paint is required because of incompatible or unsatisfactory surfaces for repainting, remove paint to extent required by conditions.
  - 1. Application: Apply paint removers according to paint-remover manufacturer's written instructions. Do not allow paint removers to remain on surface for periods longer than those indicated or recommended in writing by manufacturer.
    - a. Apply materials to all surfaces, corners, contours, and interstices, to provide a uniform final appearance without streaks.
    - b. After work is complete, remove protection no longer required. Remove tape and adhesive marks.
  - 2. Brushes: Use brushes that are resistant to chemicals being used.
    - a. Metal Substrates: If using wire brushes on metal, use brushes of same metal composition as metal being treated.
    - b. Wood Substrates: Do not use wire brushes.

3. Spray Equipment: Use spray equipment that provides controlled application at volume and pressure indicated, measured at nozzle. Adjust pressure and volume to ensure that spray methods do not damage surfaces.
    - a. Equip units with pressure gages.
    - b. Unless otherwise indicated, hold spray nozzle at least 6 inches (150 mm) from surface and apply material in horizontal, back-and-forth sweeping motion, overlapping previous strokes to produce uniform coverage.
    - c. For chemical spray application, use low-pressure tank or chemical pump suitable for chemical indicated, equipped with nozzle having a cone-shaped spray.
  - B. Paint Removal with Hand Tools: Remove paint manually using hand-held scrapers, wire brushes, sandpaper, and metallic wool as appropriate for the substrate material.
  - C. Paint Removal with Alkaline Paste Paint Remover:
    1. Remove loose and peeling paint using water, scrapers, stiff brushes, or a combination of these. Let surface dry thoroughly.
    2. Apply paint remover to dry, painted surface with brushes.
    3. Allow paint remover to remain on surface for period recommended in writing by manufacturer or as determined by preconstruction testing.
    4. Rinse with hot water applied by low-pressure spray to remove chemicals and paint residue.
    5. Use mechanical methods recommended in writing by manufacturer to remove chemicals and paint residue.
    6. Repeat process if necessary to remove all paint.
  - D. Paint Removal with Solvent-Type Paste Paint Remover:
    1. Remove loose and peeling paint using water, scrapers, stiff brushes, or a combination of these. Let surface dry thoroughly.
    2. Apply thick coating of paint remover to dry, painted surface with natural-fiber cleaning brush, deep-nap roller, or large paintbrush. Apply in one or two coats according to manufacturer's written instructions.
    3. Allow paint remover to remain on surface for period recommended in writing by manufacturer or as determined by preconstruction testing.
    4. Rinse with hot water applied by low-pressure spray to remove chemicals and paint residue.
    5. Use mechanical methods recommended in writing by manufacturer to remove chemicals and paint residue.
    6. Repeat process if necessary to remove all paint.
- 3.6 SUBSTRATE REPAIR
- A. General: Repair substrate surface defects that are inconsistent with the surface appearance of adjacent materials and finishes.
  - B. Wood Substrate:

1. Repair wood defects including dents and gouges more than 1/8 inch (3 mm) in size and all holes and cracks by filling with wood-patching compound and sanding smooth. Reset or remove protruding fasteners.
2. Where existing paint is allowed to remain, sand irregular buildup of paint, runs, and sags to achieve a uniformly smooth surface.

Cementitious Material Substrate:

3. General: Repair defects including dents and chips more than 1/4 inch (6 mm) in size and all holes and cracks by filling with cementitious patching compound and sanding smooth. Remove protruding fasteners.
4. New and Bare Plaster: Neutralize surface of plaster with mild acid solution as recommended in writing by paint manufacturer. In lieu of acid neutralization, follow manufacturer's written instruction for primer or transition coat over alkaline plaster surfaces.
5. Concrete, Cement Plaster, and Other Cementitious Products: Remove efflorescence, chalk, dust, dirt, grease, oils, and release agents. If surfaces are too alkaline to paint, correct this condition before painting.

C. Gypsum-Plaster and Gypsum-Board Substrates:

1. Repair defects including dents and chips more than 1/8 inch (3 mm) in size and all holes and cracks by filling with gypsum-plaster patching compound and sanding smooth. Remove protruding fasteners.
2. Rout out surface cracks to remove loose, unsound material; fill with patching compound and sand smooth.

D. Metal Substrate:

1. Preparation: Treat repair locations by wire-brushing and solvent cleaning. Use chemical]or mechanical rust removal method to clean off rust.
2. Defects in Metal Surfaces: Repair non-load-bearing defects in existing metal surfaces, including dents and gouges more than 1/16 inch (6 mm) across and all holes and cracks by filling with metal-patching compound and sanding smooth. Remove burrs and protruding fasteners.
3. Priming: Prime iron and steel surfaces immediately after repair to prevent flash rusting. Stripe paint corners, crevices, bolts, welds, and sharp edges. Apply two coats to surfaces that are inaccessible after completion of the Work.

### 3.7 PAINT APPLICATION, GENERAL

- A. Comply with manufacturers' written instructions for application methods unless otherwise indicated in this Section.
- B. Prepare surfaces to be painted according to the Surface-Preparation Schedule and with manufacturer's written instructions for each substrate condition.
- C. Apply a transition coat over incompatible existing coatings.

- D. Metal Substrate: Stripe paint corners, crevices, bolts, welds, and sharp edges before applying full coat. Apply two coats to surfaces that are inaccessible after completion of the Work. Tint stripe coat different than the main coating and apply with brush.
- E. Blending Painted Surfaces: When painting new substrates patched into existing surfaces or touching up missing or damaged finishes, apply coating system specified for the specific substrate. Apply final finish coat over entire surface from edge to edge and corner to corner.

### 3.8 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage paint-remover manufacturer's factory-authorized service representative for consultation and Project-site inspection and to provide on-site assistance when requested by Architect.

### 3.9 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

### 3.10 SURFACE-PREPARATION SCHEDULE

- A. General: Before painting, prepare surfaces for painting according to applicable requirements specified in this schedule.
  - 1. Examine surfaces to evaluate each surface condition according to paragraphs below.
  - 2. Where existing degree of soiling prevents examination, preclean surface and allow it to dry before making an evaluation.
  - 3. Repair substrate defects according to "Substrate Repair" Article.
- B. Surface Preparation for MPI DSD 0 Degree of Surface Degradation:
  - 1. Surface Condition: Existing paint film in good condition and tightly adhered.
  - 2. Paint Removal: Not required.
  - 3. Preparation for Painting: Wash surface by detergent cleaning; use solvent cleaning where needed. Roughen or degloss cleaned surfaces to ensure paint adhesion according to paint manufacturer's written instructions.

C. Surface Preparation for MPI DSD 1 Degree of Surface Degradation:

1. Surface Condition: Paint film cracked or broken but adhered.
2. Paint Removal: Scrape by hand-tool cleaning methods to remove loose paint until only tightly adhered paint remains.
3. Preparation for Painting: Wash surface by detergent cleaning; use other cleaning methods for small areas of bare substrate if required. Roughen, degloss, and sand the cleaned surfaces to ensure paint adhesion and a smooth finish according to paint manufacturer's written instructions.

D. Surface Preparation for MPI DSD 2 Degree of Surface Degradation:

1. Surface Condition: Paint film loose, flaking, or peeling.
2. Paint Removal: Remove loose, flaking, or peeling paint film by hand-tool or chemical paint-removal methods.
3. Preparation for Painting: Wash surface by detergent cleaning; use solvent cleaning where needed. Use other cleaning methods for small areas of bare substrate if required. Sand surfaces to smooth remaining paint film edges. Prepare bare cleaned surface to be painted according to paint manufacturer's written instructions for substrate construction materials.

E. Surface Preparation for MPI DSD 3 Degree of Surface Degradation:

1. Surface Condition: Paint film severely deteriorated, obscuring fine architectural detail work because of paint-layer buildup and surface indicated to have paint completely removed.
2. Paint Removal: Completely remove paint film by hand-tool or chemical paint-removal methods. Remove rust.
3. Preparation for Painting: Prepare bare cleaned surface according to paint manufacturer's written instructions for substrate construction materials.

F. Surface Preparation for MPI DSD 4 Degree of Surface Degradation:

1. Surface Condition: Missing material, small holes and openings, and deteriorated or corroded substrate.
2. Substrate Preparation: Repair, replace, and treat substrate according to "Substrate Repair" Article and requirements in other Specification Sections.
3. Preparation for Painting: Sand substrate surfaces to smooth remaining paint film edges and prepare according to paint manufacturer's written instructions for substrate construction materials. Remove rust.
4. Painting: Paint as required for MPI DSD 2 degree of surface degradation.

END OF SECTION 090190.52

SECTION 090561.13 - MOISTURE VAPOR EMISSION CONTROL

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Fluid-applied, resin-based, membrane-forming systems that control the moisture-vapor-emission rate of high-moisture, interior concrete, to prepare it for floor covering installation.

1.3 DEFINITIONS

- A. MVE: Moisture vapor emission.
- B. MVER: Moisture vapor emission rate.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Sustainable Design Submittals.

1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For manufacturer.
- B. Product Test Reports: For each MVE-control system, for tests performed by manufacturer and witnessed by a qualified testing agency.
- C. Preinstallation testing reports.
- D. Field quality-control reports.

## 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Employs factory-trained personnel who are available for consultation and Project-site inspection.
- B. Installer Qualifications: An authorized representative who is trained and approved by manufacturer.

## 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials in original packages and containers, with seals unbroken, bearing manufacturer's labels indicating directions for storage and mixing with other components.

## 1.8 FIELD CONDITIONS

- A. Environmental Limitations: Comply with MVE-control system manufacturer's written instructions for substrate and ambient temperatures, humidity, ventilation, and other conditions affecting system installation.
  - 1. Store system components in a temperature-controlled environment and protected from weather and at ambient temperature of not less than 65 deg F (18 deg C) and not more than 85 deg F (29.4 deg C) at least 48 hours before use.
  - 2. Maintain ambient temperature and relative humidity in installation areas within range recommended in writing by MVE-control system manufacturer, but not less than 65 deg F (18 deg C) or more than 85 deg F (29.4 deg C) and not less than 40 or more than 60 percent relative humidity, for 48 hours before installation, during installation, and for 48 hours after installation unless longer period is recommended in writing by manufacturer.
  - 3. Install MVE-control systems where concrete surface temperatures will remain a minimum of 5 deg F (3 deg C) higher than the dew point for ambient temperature and relative humidity conditions in installation areas for 48 hours before installation, during installation, and for 48 hours after installation unless longer period is recommended in writing by manufacturer.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. MVE-Control System Capabilities: Capable of suppressing MVE without failure where installed on concrete that exhibits the following conditions:
  - 1. MVER: Maximum of water to meet flooring manufacturer's requirements when tested according to ASTM F1869.
  - 2. Relative Humidity: Maximum 100 percent when tested according to ASTM F2170 using in situ probes.

- B. Water-Vapor Transmission: Through MVE-control system, maximum transmission to meet flooring manufacturer's requirements when tested according to ASTM E96/E96M.
- C. Tensile Bond Strength: For MVE-control system, greater than 200 psi (1.38 MPa) with failure in the concrete according to ASTM D7234.

## 2.2 MVE-CONTROL SYSTEM

- A. Manufacturers: Subject to compliance with flooring manufacturer's requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
  - 1. ARDEX Americas.
  - 2. Advanced Moisture Control, Inc.
  - 3. Custom Building Products.
  - 4. Floor Seal Technology, Inc.
  - 5. H.B. Fuller Construction Products Inc. / TEC.
  - 6. KOSTER American Corporation.
  - 7. Laticrete International, Inc.
  - 8. MAPEI Corporation.
  - 9. Master Builders Solutions.
  - 10. USG Corporation.
  - 11. Approved equal.
- B. MVE-Control System: ASTM F3010-qualified, fluid-applied, two-component, epoxy-resin, membrane-forming system; formulated for application on concrete substrates to reduce MVER to level required for installation of floor coverings indicated and acceptable to manufacturers of floor covering products indicated, including adhesives. MVE system must be fully compatible with the flooring manufacturer's adhesives.
  - 1. Substrate Primer: Provide MVE-control system manufacturer's concrete-substrate primer if required for system indicated by substrate conditions.
  - 2. Cementitious Underlayment Primer: If required for subsequent installation of cementitious underlayment products, provide MVE-control system manufacturer's primer to ensure adhesion of products to MVE-control system.

## 2.3 ACCESSORIES

- A. Patching and Leveling Material: Moisture-, mildew-, and alkali-resistant product recommended in writing by MVE-control system manufacturer and with minimum of 3000-psi (20.68-MPa) compressive strength after 28 days when tested according to ASTM C109/C109M.
- B. Crack-Filling Material: Resin-based material recommended in writing by MVE-control system manufacturer for sealing concrete substrate crack repair.
- C. Cementitious Underlayment: If required to maintain manufacturer's warranty, provide MVE-control system manufacturer's hydraulic cement-based underlayment.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for maximum moisture content, installation tolerances, and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.
  - 1. Installation of system indicates acceptance of surfaces and conditions.

#### 3.2 PREPARATION

- A. Preinstallation Testing:
  - 1. Testing Agency: Engage a qualified testing agency to perform tests.
  - 2. Alkalinity Testing: Perform pH testing according to ASTM F710. Install MVE-control system in areas where pH readings where readings do not meet flooring manufacturer's installation requirements.
  - 3. Moisture Testing: Perform tests so that each test area does not exceed 1000 sq. ft. (304.8 sq. m), and perform no fewer than three tests in each installation area and with test areas evenly spaced in installation areas.
    - a. Anhydrous Calcium Chloride Test: ASTM F1869. Install MVE-control system in locations where concrete substrate MVER exceeds maximum rate to meet flooring manufacturer's installation requirements.
    - b. Internal Relative Humidity Test: Using in situ probes, ASTM F2170. Install MVE-control system in locations where concrete substrates exhibit relative humidity level greater than those acceptable to the flooring manufacturer.
  - 4. Tensile-Bond-Strength Testing: For typical locations indicated to receive installation of MVE-control system, install minimum 100-sq. ft. (9.29-sq. m) area of MVE-control system to prepared concrete substrate and test according to ASTM D7234.
    - a. Proceed with installation only where tensile bond strength is greater than 200 psi (1.38 MPa) with failure in the concrete.
- B. Concrete Substrates: Prepare and clean substrates according to MVE-control system manufacturer's written instructions to ensure adhesion of system to concrete.
  - 1. Remove coatings and other substances that are incompatible with MVE-control system and that contain soap, wax, oil, or silicone, using mechanical methods recommended in writing by MVE-control system manufacturer. Do not use solvents.
  - 2. Provide concrete surface profile complying with ICRI 310.2R CSP 3 by shot blasting using apparatus that abrades the concrete surface with shot, contains the dispensed shot within the apparatus, and recirculates the shot by vacuum pickup.

3. After shot blasting, repair damaged and deteriorated concrete according to MVE-control system manufacturer's written instructions.
  4. Protect substrate voids and joints to prevent resins from flowing into or leaking through them.
  5. Fill surface depressions and irregularities with patching and leveling material.
  6. Fill surface cracks, grooves, control joints, and other nonmoving joints with crack-filling material.
  7. Allow concrete to dry, undisturbed, for period recommended in writing by MVE-control system manufacturer after surface preparation, but not less than 24 hours.
  8. Before installing MVE-control systems, broom sweep and vacuum prepared concrete.
- C. Protect walls, floor openings, electrical openings, door frames, and other obstructions during installation.

### 3.3 INSTALLATION

- A. Install MVE-control system according to ASTM F3010 and manufacturer's written instructions to produce a uniform, monolithic surface free of surface deficiencies such as pin holes, fish eyes, and voids.
1. Install primers as required to comply with manufacturer's written instructions.
- B. Do not apply MVE-control system across substrate expansion, isolation, and other moving joints.
- C. Apply system, including component coats if any, in thickness recommended in writing by MVE-control system manufacturer for MVER indicated by preinstallation testing.
- D. Cure MVE-control system components according to manufacturer's written instructions. Prevent contamination or other damage during installation and curing processes.
- E. After curing, examine MVE-control system for surface deficiencies. Repair surface deficiencies according to manufacturer's written instructions.
- F. Install cementitious underlayment over cured membrane if required to maintain manufacturer's warranty and in thickness required to maintain the warranty.

### 3.4 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform installation inspections.
- B. Installation Inspections: Inspect substrate preparation and installation of system components to ensure compliance with manufacturer's written instructions and to ensure that a complete MVE-control system is installed without deficiencies.
1. Verify that surface preparation meets requirements.
  2. Verify that component coats and complete MVE-control-system film thicknesses comply with manufacturer's written instructions.

3. Verify that MVE-control-system components and installation areas that evidence deficiencies are repaired according to manufacturer's written instructions.
- C. MVE-control system will be considered defective if it does not pass inspections.

### 3.5 PROTECTION

- A. Protect MVE-control system from damage, wear, dirt, dust, and other contaminants before floor covering installation. Use protective methods and materials, including temporary coverings, recommended in writing by MVE-control system manufacturer.
- B. Do not allow subsequent preinstallation examination and testing for floor covering installation to damage, puncture, or otherwise compromise the MVE-control system membrane.

END OF SECTION 090561.13

## SECTION 096513 - RESILIENT BASE AND ACCESSORIES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Thermoplastic-rubber base.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Sustainable Design Submittals.
- C. Samples: For each exposed product and for each color and texture specified, not less than 12 inches (300 mm) long.
- D. Samples for Initial Selection: For each type of product indicated.
- E. Samples for Verification: For each type of product indicated and for each color, texture, and pattern required in manufacturer's standard-size Samples, but not less than 12 inches (300 mm) long.
- F. Product Schedule: For resilient base and accessory products.

#### 1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Furnish not less than 10 linear feet (3 linear m) for every 500 linear feet (150 linear m) or fraction thereof, of each type, color, pattern, and size of resilient product installed.

#### 1.5 QUALITY ASSURANCE

- A. Mockups: Build mockups to verify selections made under Sample submittals, to demonstrate aesthetic effects, and to set quality standards for materials and execution.

1. Coordinate mockups in this Section with mockups specified in other Sections.
2. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
3. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store resilient products and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F (10 deg C) or more than 90 deg F (32 deg C).

#### 1.7 FIELD CONDITIONS

- A. Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F (21 deg C) or more than 95 deg F (35 deg C), in spaces to receive resilient products during the following periods:
  1. 48 hours before installation.
  2. During installation.
  3. 48 hours after installation.
- B. After installation and until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F (13 deg C) or more than 95 deg F (35 deg C).
- C. Install resilient products after other finishing operations, including painting, have been completed.

### PART 2 - PRODUCTS

#### 2.1 THERMOPLASTIC-RUBBER BASE

- A. Manufacturers: Subject to compliance with requirements available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  1. Allstate Flooring.
  2. Armstrong World Industries, Inc.
  3. Flexco.
  4. Johnsonite; a Tarkett company.
  5. Nora by Interface.
  6. Roppe Corporation.
  7. VPI Corporation.
  8. Approved equal.

- B. Product Standard: ASTM F1861, Type TP (rubber, thermoplastic).
  - 1. Group: I (solid, homogeneous).
  - 2. Style and Location:
    - a. Style B, Cove: Provide in areas with resilient floor coverings.
- C. Thickness: 0.125 inch (3.2 mm).
- D. Height: 4 inches (102 mm) or match existing heights of base that was removed.
- E. Lengths: Coils in manufacturer's standard length.
- F. Outside Corners: Preformed.
- G. Inside Corners: Preformed.
- H. Colors: As selected by Architect from manufacturer's full range of colors available.

## 2.2 INSTALLATION MATERIALS

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland-cement-based or blended hydraulic-cement-based formulation provided or approved by resilient-product manufacturer for applications indicated.
- B. Adhesives: Water-resistant type recommended by resilient-product manufacturer for resilient products and substrate conditions indicated.
- C. Stair-Tread Nose Filler: Two-part epoxy compound recommended by resilient stair-tread manufacturer to fill nosing substrates that do not conform to tread contours.
- D. Floor Polish: Provide protective, liquid floor-polish products recommended by resilient stair-tread manufacturer.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
  - 1. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks, ridges, depressions, scale, and foreign deposits that might interfere with adhesion of resilient products.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.
  - 1. Installation of resilient products indicates acceptance of surfaces and conditions.

### 3.2 PREPARATION

- A. Prepare substrates according to manufacturer's written instructions to ensure adhesion of resilient products.
- B. Concrete Substrates for Resilient Stair Accessories: Prepare horizontal surfaces according to ASTM F710.
  - 1. Verify that substrates are dry and free of curing compounds, sealers, and hardeners.
  - 2. Remove substrate coatings and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, using mechanical methods recommended by manufacturer. Do not use solvents.
  - 3. Alkalinity and Adhesion Testing: Perform tests recommended by manufacturer. Proceed with installation only after substrate alkalinity falls within range on pH scale recommended by manufacturer in writing, but not less than 5 or more than 9 pH.
  - 4. Moisture Testing: Perform tests so that each test area does not exceed 200 sq. ft. (18.6 sq. m), and perform no fewer than three tests in each installation area and with test areas evenly spaced in installation areas.
    - a. Anhydrous Calcium Chloride Test: ASTM F1869. Proceed with installation only after substrates have maximum moisture-vapor-emission rate of 3 lb of water/1000 sq. ft. (1.36 kg of water/92.9 sq. m) in 24 hours or maximum rate acceptable to the manufacturer.
    - b. Relative Humidity Test: Using in-situ probes, ASTM F2170. Proceed with installation only after substrates have a maximum 75 percent relative humidity level measurement or maximum rate acceptable to the manufacturer.
    - c. Fill cracks, holes, and depressions in substrates with trowelable leveling and patching compound; remove bumps and ridges to produce a uniform and smooth substrate.
- C. Do not install resilient products until materials are the same temperature as space where they are to be installed.
  - 1. At least 48 hours in advance of installation, move resilient products and installation materials into spaces where they will be installed.
- D. Immediately before installation, sweep and vacuum clean substrates to be covered by resilient products.

### 3.3 RESILIENT BASE INSTALLATION

- A. Comply with manufacturer's written instructions for installing resilient base.
- B. Apply resilient base to walls, columns, pilasters, casework and cabinets in toe spaces, and other permanent fixtures in rooms and areas where base is required.
- C. Install resilient base in lengths as long as practical without gaps at seams and with tops of adjacent pieces aligned.

- D. Tightly adhere resilient base to substrate throughout length of each piece, with base in continuous contact with horizontal and vertical substrates.
- E. Do not stretch resilient base during installation.
- F. On masonry surfaces or other similar irregular substrates, fill voids along top edge of resilient base with manufacturer's recommended adhesive filler material.
- G. Preformed Corners: Install preformed corners before installing straight pieces.

#### 3.4 CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protecting resilient products.
- B. Perform the following operations immediately after completing resilient-product installation:
  - 1. Remove adhesive and other blemishes from surfaces.
  - 2. Sweep and vacuum horizontal surfaces thoroughly.
  - 3. Damp-mop horizontal surfaces to remove marks and soil.
- C. Protect resilient products from mars, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- D. Cover resilient products subject to wear and foot traffic until Substantial Completion.

END OF SECTION 096513

## SECTION 096519 – LUXURY VINYL COMPOSITION TILE FLOORING

### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.2 SUMMARY

- A. Section Includes:
  - 1. Commercial Luxury Vinyl Composition Tile.

### 1.3 RELATED SECTIONS

- A. Section 090561.13, “Moisture Vapor Emission Control”.

### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Samples: Full-size units of each color, texture, and pattern of floor tile required.
- C. Samples for Initial Selection: For each type of floor tile indicated.
- D. Samples for Verification: Full-size units of each color and pattern of floor tile required.

### 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer.

### 1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For each type of floor tile to include in maintenance manuals.

### 1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Floor Tile: Furnish one box for every 50 boxes or fraction thereof, of each type, color, and pattern of floor tile installed.

## 1.8 QUALITY ASSURANCE

- A. Installer Qualifications: An entity that employs installers and supervisors who are competent in techniques required by manufacturer for floor tile installation and seaming method indicated.
  - 1. Engage an installer who employs workers for this Project who are trained or certified by floor tile manufacturer for installation techniques required.

## 1.9 DELIVERY, STORAGE, AND HANDLING

- A. Store floor tile and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F (10 deg C) or more than 90 deg F (32 deg C). Store floor tiles on flat surfaces.

## 1.10 FIELD CONDITIONS

- A. Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F (21 deg C) or more than 95 deg F (35 deg C), in spaces to receive floor tile during the following periods:
  - 1. 48 hours before installation.
  - 2. During installation.
  - 3. 48 hours after installation.
- B. After installation and until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F (13 deg C) or more than 95 deg F (35 deg C).
- C. Close spaces to traffic during floor tile installation.
- D. Close spaces to traffic for 48 hours after floor tile installation.
- E. Install floor tile after other finishing operations, including painting, have been completed.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Test-Response Characteristics: For resilient floor tile, as determined by testing identical products according to ASTM E648 or NFPA 253 by a qualified testing agency.
  - 1. Critical Radiant Flux Classification: Class I, not less than 0.45 W/sq. cm.

## 2.2 LUXURY VINYL TILES

- A. Commercial Grade Luxury Vinyl Floor Tiles: Manufacturer's luxury vinyl tiles consisting of commercial UV-cured coating, performance wear layer, with printed visual layer, base layers, with smooth wearing surface and manufacturer's standard factory-applied, protective coating.

## 2.3 Luxury Vinyl Tile

- A. District-Standard & Basis-of-Design Manufacturer: Mohawk Group; Bolder 2.5, Hot and Heavy Collection II, or architect-approved equal.
- B. Construction: Flexible LVT. Class III, Type B-embossed.
- C. Thickness: 2.5 mm.
- D. Wear Layer: 20 mil.
- E. Static Load: Passes, modified at 1000 psi per ASTM F970.
- F. Residual Indentation: Passes per ASTM F1914.
- G. Static Coefficient of Friction: more than or equal to 0.5 per ASTM D2047.
- H. Flame Spread: Class 1, 0.45W/cm<sup>2</sup> or more, in accordance with ASTM E648.
- I. Smoke Evolution: 450 or less, Passes per ASTM E662.
- J. Chemical Resistance: Delta E less than 8 per ASTM F925.
- K. Resistance to Light: Delta E less than 8 per ASTM F1515.
- L. Resistance to Heat: Passes per ASTM F1514.
- M. Dimensional Stability: Passes per ASTM F2199.
- N. Flexibility: per ASTM F137.
- O. Size: 18-inches x 36-inches.
- P. Edge Profile: Square.
- Q. Colors: As selected from manufacturer's full range of colors available.
- R. Factory Finish: M-Force Ultra.
- S. Gloss: Low gloss.
- T. Warranty: Manufacturer's standard 20-year commercial warranty.
- U. Installation Method: Glued down, in pattern as selected by architect.

- V. Adhesives: As recommended by the manufacturer for high moisture, and high relative humidity concrete slab conditions. Adhesive must come from the same manufacturer as the floor tiles.

## 2.4 INSTALLATION MATERIALS

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland-cement-based or blended hydraulic-cement-based formulation provided or approved by floor tile manufacturer for applications indicated.
- B. Adhesives: Water-resistant type recommended by floor tile and adhesive manufacturers to suit floor tile and substrate conditions indicated.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
  - 1. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks, ridges, depressions, scale, and foreign deposits that might interfere with adhesion of floor tile.
  - 2. Pre-Installation Testing: Conduct pre-installation moisture testing at intervals recommended by the manufacturer. Perform bond tests and pH test, as recommended by the flooring manufacturer. Adhesive selection shall be based on the results of testing.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Prepare substrates according to floor tile manufacturer's written instructions to ensure adhesion of resilient products.
- B. Concrete Substrates: Prepare according to ASTM F710.
  - 1. Verify that substrates are dry and free of curing compounds, sealers, and hardeners.
  - 2. Remove substrate coatings and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, using mechanical methods recommended by floor tile manufacturer. Do not use solvents.
  - 3. Alkalinity and Adhesion Testing: Perform tests recommended by floor tile manufacturer. Proceed with installation only after substrate alkalinity falls within range on pH scale recommended by manufacturer in writing, but not less than 8 or more than 9 pH. If pH exceeds the manufacturer's tolerances, the Contractor shall install manufacturer's approved coating.

4. Moisture Testing: Unless the flooring manufacturer has more stringent requirements, perform tests so that each test area does not exceed 200 sq. ft. (18.6 sq. m), and perform no fewer than three tests in each installation area and with test areas evenly spaced in installation areas.
  - a. Anhydrous Calcium Chloride Test: ASTM F1869. Proceed with installation only after substrates have maximum moisture-vapor-emission rate acceptable to the flooring manufacturer and compliance with the adhesive requirements.
  - b. Relative Humidity Test: Using in-situ probes, ASTM F2170. Proceed with installation only after substrates have a rate acceptable to the flooring manufacturer and and compliance with the adhesive requirements.
  - c. Fill cracks, holes, and depressions in substrates with trowelable leveling and patching compound; remove bumps and ridges to produce a uniform and smooth substrate.
  - d. Selection of flooring adhesive must meet the requirements of the flooring manufacturer.
- C. Do not install floor tiles until materials are the same temperature as space where they are to be installed.
  1. At least 48 hours in advance of installation, move resilient floor tile and installation materials into spaces where they will be installed.
- D. Immediately before installation, sweep and vacuum clean substrates to be covered by resilient floor tile.

### 3.3 FLOOR TILE INSTALLATION

- A. Comply with manufacturer's written instructions for installing floor tile.
- B. Install Moisture Vapor Emission Control membrane on all surfaces to receive new resilient flooring materials.
- C. Lay out floor tiles from center marks established with principal walls, discounting minor offsets, so tiles at opposite edges of room are of equal width. Adjust as necessary to avoid using cut widths that equal less than one-half tile at perimeter.
  1. Lay tiles square with room axis in pattern as determined by the Architect.
- D. Match floor tiles for color and pattern by selecting tiles from cartons in the same sequence as manufactured and packaged, if so numbered. Discard broken, cracked, chipped, or deformed tiles.
  1. Lay tiles with grain direction alternating in adjacent tiles (basket-weave pattern) or as shown on the drawings.

- E. Scribe, cut, and fit floor tiles to butt neatly and tightly to vertical surfaces and permanent fixtures including built-in furniture, cabinets, pipes, outlets, and door frames.
- F. Extend floor tiles into toe spaces, door reveals, closets, and similar openings. Extend floor tiles to center of door openings.
- G. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on floor tiles as marked on substrates. Use chalk or other nonpermanent marking device.
- H. Adhere floor tiles to substrates using a full spread of adhesive applied to substrate to produce a completed installation without open cracks, voids, raising and puckering at joints, telegraphing of adhesive spreader marks, and other surface imperfections.
- I. Accessories: Install according to manufacturer's written instructions.

### 3.4 CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protecting floor tile.
- B. Perform the following operations immediately after completing floor tile installation:
  - 1. Remove adhesive and other blemishes from surfaces.
  - 2. Sweep and vacuum surfaces thoroughly.
  - 3. Damp-mop surfaces to remove marks and soil.
- C. Protect floor tile from mars, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- D. Sealers and Finish Coats: No sealer or finish coats per Owner's request.
- E. Cover floor tile until Substantial Completion.

END OF SECTION 096519

## SECTION 096813 - TILE CARPETING

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes modular carpet tile.
- B. Related Requirements:
  - 1. Section 096513 "Resilient Base and Accessories",
  - 2. Section 090561.13, "Moisture Vapor Emission Control".

#### 1.3 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.
  - 1. Review methods and procedures related to carpet tile installation including, but not limited to, the following:
    - a. Review delivery, storage, and handling procedures.
    - b. Review ambient conditions and ventilation procedures.
    - c. Review subfloor preparation procedures.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include manufacturer's written data on physical characteristics, durability, and fade resistance.
  - 2. Include manufacturer's written installation recommendations for each type of substrate.
- B. Samples: For each of the following products and for each color and texture required. Label each Sample with manufacturer's name, material description, color, pattern, and designation indicated on Drawings and in schedules.
  - 1. Carpet Tile: Full-size Sample.
  - 2. Exposed Edge, Transition, and Other Accessory Stripping: 12-inch- (300-mm-) long Samples.

- C. Samples for Initial Selection: For each type of carpet tile.
  - 1. Include Samples of exposed edge, transition, and other accessory stripping involving color or finish selection.
- D. Samples for Verification: For each of the following products and for each color and texture required. Label each Sample with manufacturer's name, material description, color, pattern, and designation indicated on Drawings and in schedules.
  - 1. Carpet Tile: Full-size Sample.
  - 2. Exposed Edge, Transition, and Other Accessory Stripping: 12-inch- (300-mm-) long Samples.
- E. Product Schedule: For carpet tile. Use same designations indicated on Drawings.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer.
- B. Product Test Reports: For carpet tile, for tests performed by a qualified testing agency.
- C. Sample Warranty: For special warranty.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For carpet tiles to include in maintenance manuals. Include the following:
  - 1. Methods for maintaining carpet tile, including cleaning and stain-removal products and procedures and manufacturer's recommended maintenance schedule.
  - 2. Precautions for cleaning materials and methods that could be detrimental to carpet tile.

#### 1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Carpet Tile: Full-size units equal to 5 percent of amount installed for each type indicated, but not less than 10 sq. yd. (8.3 sq. m).

#### 1.8 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who is certified by the International Certified Floorcovering Installers Association at the Commercial II certification level.

1.9 DELIVERY, STORAGE, AND HANDLING

- A. Comply with CRI's "CRI Carpet Installation Standard."

1.10 FIELD CONDITIONS

- A. Comply with CRI's "CRI Carpet Installation Standard" for temperature, humidity, and ventilation limitations.
- B. Environmental Limitations: Do not deliver or install carpet tiles until spaces are enclosed and weathertight, wet-work in spaces is complete and dry, and ambient temperature and humidity conditions are maintained at levels planned for building occupants during the remainder of the construction period.
- C. Do not install carpet tiles over concrete slabs until slabs have cured and are sufficiently dry to bond with adhesive and concrete slabs have pH range recommended by carpet tile manufacturer.

PART 2 - PRODUCTS

2.1 CARPET TILE

- A. Basis-of-Design: J&J Flooring; Kintex, Umba II Plank, or Architect-Approved equivalent.
- B. Color: As selected by Architect from manufacturer's full range.
- C. Construction: Textile Composite.
- D. Wear Layer: 100% Solution Dyed Polyester.
- E. Backing: Polyester Felt Cushion.
- F. Dye Method: Solution Dyed.
- G. Total Weight: 4.5-5.2 ounces per square foot average.
- H. Total Thickness: 0.205 Inches.
- I. Dimensions: 18-inches x 36-inches modules.
- J. Adhesive and Materials Warranty: Manufacturer's standard lifetime warranty.
- K. Applied Treatments:
  - 1. Soil-Resistance Treatment: Manufacturer's standard treatment.
  - 2. Antimicrobial Treatment: Manufacturer's standard treatment.
- L. Performance Characteristics:

1. Critical Radiant Flux Classification: Not less than 0.45 W/sq. cm according to NFPA 253.

## 2.2 INSTALLATION ACCESSORIES

- A. Trowelable Leveling and Patching Compounds: Latex-modified, hydraulic-cement-based formulation provided or recommended by carpet tile manufacturer.
- B. Adhesives: Water-resistant, mildew-resistant, nonstaining, pressure-sensitive type to suit products and subfloor conditions indicated, that comply with flammability requirements for installed carpet tile, and are recommended by carpet tile manufacturer for releasable installation.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for maximum moisture content, alkalinity range, installation tolerances, and other conditions affecting carpet tile performance.
- B. Examine carpet tile for type, color, pattern, and potential defects.
- C. Concrete Slabs: Verify that finishes comply with requirements specified in Section 033000 "Cast-in-Place Concrete" and that surfaces are free of cracks, ridges, depressions, scale, and foreign deposits.
  1. Moisture Testing: Perform tests so that each test area does not exceed 200 sq. ft. (18.6 sq. m, and perform no fewer than three tests in each installation area and with test areas evenly spaced in installation areas.
    - a. Maximum RH of Concrete: 100%
    - b. Maximum pH reading: 11.0 using pH strips.
    - c. Perform additional moisture tests recommended in writing by adhesive and carpet tile manufacturers. Proceed with installation only after substrates pass testing.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. General: Comply with CRI's "Carpet Installation Standards" and with carpet tile manufacturer's written installation instructions for preparing substrates indicated to receive carpet tile.
- B. Use trowelable leveling and patching compounds, according to manufacturer's written instructions, to fill cracks, holes, depressions, and protrusions in substrates. Fill or level cracks,

holes and depressions 1/8 inch (3 mm) wide or wider, and protrusions more than 1/32 inch (0.8 mm) unless more stringent requirements are required by manufacturer's written instructions.

- C. Concrete Substrates: Remove coatings, including curing compounds, and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, without using solvents. Use mechanical methods recommended in writing by adhesive and carpet tile manufacturers.
- D. Broom and vacuum clean substrates to be covered immediately before installing carpet tile.

### 3.3 INSTALLATION

- A. General: Comply with CRI's "CRI Carpet Installation Standard," Section 18, "Modular Carpet" and with carpet tile manufacturer's written installation instructions.
- B. Installation Method: As recommended in writing by carpet tile manufacturer.
- C. Maintain dye-lot integrity. Do not mix dye lots in same area.
- D. Maintain pile-direction patterns recommended in writing by carpet tile manufacturer.
- E. Cut and fit carpet tile to butt tightly to vertical surfaces, permanent fixtures, and built-in furniture including cabinets, pipes, outlets, edgings, thresholds, and nosings. Bind or seal cut edges as recommended by carpet tile manufacturer.
- F. Extend carpet tile into toe spaces, door reveals, closets, open-bottomed obstructions, removable flanges, alcoves, and similar openings.
- G. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on carpet tile as marked on subfloor. Use nonpermanent, nonstaining marking device.
- H. Install pattern parallel to walls and borders.

### 3.4 CLEANING AND PROTECTION

- A. Perform the following operations immediately after installing carpet tile:
  - 1. Remove excess adhesive and other surface blemishes using cleaner recommended by carpet tile manufacturer.
  - 2. Remove yarns that protrude from carpet tile surface.
  - 3. Vacuum carpet tile using commercial machine with face-beater element.
- B. Protect installed carpet tile to comply with CRI's "Carpet Installation Standard," Section 20, "Protecting Indoor Installations."

WINDOWS REPLACEMENT - LINDENWOLD HIGH SCHOOL  
REGAN YOUNG ENGLAND BUTERA, PC PROJECT #5773D

- C. Protect carpet tile against damage from construction operations and placement of equipment and fixtures during the remainder of construction period. Use protection methods indicated or recommended in writing by carpet tile manufacturer.

END OF SECTION 096813

## SECTION 123661.16 - SOLID SURFACING WINDOWSILLS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Solid Surface material windowsills.
- B. Related Requirements:
  - 1. Drawings and drawing specifications for non-integral sinks and plumbing fixtures and fittings.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For countertop materials.
- B. Shop Drawings: For countertops. Show materials, finishes, and edge.
  - 1. Show locations and details of joints.
  - 2. Show direction of directional pattern, if any.
- C. Samples for Initial Selection: For each type of material exposed to view.
- D. Samples for Verification: For the following products:
  - 1. Countertop material, 6 inches (150 mm) square.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For fabricator.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For solid surface material to include in maintenance manuals. Include Product Data for care products used or recommended by Installer and names, addresses, and telephone numbers of local sources for products.

1.6 FIELD CONDITIONS

- A. Field Measurements: Verify dimensions of windowsills by field measurements after base cabinets are installed but before countertop fabrication is complete.

PART 2 - PRODUCTS

2.1 SOLID SURFACE WINDOWSILL MATERIALS

- A. Solid Surface Material: Homogeneous-filled plastic resin complying with ICPA SS-1.
  - 1. Acceptable Manufacturers: Corian, Formica Corporation, Wilsonart, Richelieu, or Architect-approved equivalent.

2.2 WINDOWSILLS FABRICATION

- A. Fabricate windowsills according to solid surface material manufacturer's written instructions and to the AWI/AWMAC/WI's "Architectural Woodwork Standards."
  - 1. Grade: Custom.
- B. Configuration:
  - 1. Front: Straight, slightly eased at top.
- C. Windowsills: 3/4-inch- (19-mm-) thick, solid surface material with front edge built up with same material.
- D. Fabricate window sills with shop-applied edges plashes unless otherwise indicated. Comply with solid surface material manufacturer's written instructions for adhesives, sealers, fabrication, and finishing.
- E. Joints: Fabricate windowsills without joints.

2.3 INSTALLATION MATERIALS

- A. Adhesive: Product recommended by solid surface material manufacturer.
- B. Sealant for Windowsills: Comply with countertop manufacturer's recommendations.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates to receive solid surface material countertops and conditions under which material will be installed, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of countertops.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Install windowsills level to a tolerance of 1/8 inch in 8 feet (3 mm in 2.4 m), Do not exceed 1/64-inch (0.4-mm) difference between planes of adjacent units.
- B. Apply sealant to gaps at walls; comply with countertop manufacturer's recommendations.

END OF SECTION 123661.16